



OFFICE OF CIVIL SURGEON
KARNAL-132001



Ph. No. 0184-2267796, 2267569 Email: dhs.csknl@hrya.nic.in

NO OBJECTION CERTIFICATE

Certify that the premises of S.D. Adarsh Public School
Shri Sanatani Dharam Sabha Karnal has been
inspected. The campus of the institute has been found satisfactory from
Sanitation & Hygienic point of view. This certificate is valid for one
year from the date of issue.

-Sd-
Dy. Civil Surgeon (Health)
Karnal

No. GH/SSI/2023/304

Date:- 26/10/23

A copy is forwarded to for information and necessary
action.

Principal S.D. Adarsh Public School Karnal

ATTESTED
[Signature]
Principal
S.D. Adarsh Public School
Karnal

[Signature]
Dy. Civil Surgeon (Health)
Dy. Karnal
Health (Karnal)
[Signature]

Memo No:- 3338

Date:- 16/10/2023

Certificate
No: TC-8407

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : KNL/04335/10/2023 / Private	Sample Details	Date & Time
Sender : PRINCIPAL, S.D. ADARSH PUBLIC SCHOOL 25899	Collected By	
Location : KUNJPURA ROAD, KARNAL	Collection Date	13/10/2023 at 14:42
Sample Description : Drinking Water	Received at lab	13/10/2023 at 14:55
Latitude / Longitude : 76.979582 / 29.689245	Analysis Start Date	13/10/2023
	Analysis End Date	15/10/2023
	Sample Quantity	1000ML

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Limit (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	370	500 mg/lt.	2000 mg/lt.	IS 3025 (Part-16) : 1984 (RA 2017)
2	Total Hardness as CaCO ₃	240	200 mg/lt.	600 mg/lt.	IS 3025 (Part-21) : 2009 (RA 2019)
3	Calcium as Ca	48	75 mg/lt.	200 mg/lt.	IS 3025 (Part-40) : 1991 (RA 2019)
4	Magnesium as Mg	28.8	30 mg/lt.	100 mg/lt.	IS 3025 (Part-46) : 1994 (RA 2019)
5	Iron as Fe	0.01	1.0 mg/lt.	1.0 mg/lt.	USEPA-8008:2017
6	Chloride as Cl	62	250 mg/lt.	1000 mg/lt.	IS 3025 (Part-32) : 1988 (RA 2019)
7	Sulphate as So ₄	22	200 mg/lt.	400 mg/lt.	USEPA-8051:2017
8	Fluoride as F	0.470	1.0 mg/lt.	1.5 mg/lt.	APHA 4500-F--C
9	Nitrate as No ₃	2.1	45 mg/lt.	45 mg/lt.	APHA 4500-NO ₃ - D
10	pH @ 25°C	7.55	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 1983 (RA 2017)
11	Total Alkalinity	250	200 mg/lt.	600 mg/lt.	IS 3025 (Part-23) : 1986 (RA 2019)
12	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part-4) : 1983 (RA 2017)
13	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 1984 (RA 2018)
14	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 1984 (RA 2017)
15	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2017)

Remarks :-


- * The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

ATTESTED

Principal

END OF TEST REPORT School

Karnal





Memo No:- 3338

Date:- 16/10/2023

Subject : **Physical / Chemical Examination Report of Water Sample**



Jayindra Singh
Sample analyzed by:



16/10/23
AMIT KUMAR CHIEF CHEMIST
STATE WATER TESTING LABORATORY, KARNAL
email-chiefchemist.hr@phedharyana.gov.in

ATTESTED

[Signature]
Principal

S.D. Adarsh Public School
Karnal